

## of Victoria | Management **Construction Standards**

**Facilities** 

## **Plumbing Piping Type** .1

University

- Domestic water piping shall be type L hard drawn copper tubing to ASTM B88 or type L copper pipe to ASTM B42.
- .2 Fittings shall be copper to ASTM B16.18, brass to ASTM B16.22, press type, or solder joint.
- .3 Do not specify flexible drainage piping.
- .4 Do not specify ABS or PVC pipe under traffic areas with less than 30" cover.

## **Piping Tests** .2

Provide a hydrostatic test on all new piping at 1380 kPa (200 psig) for 8 hours. .1