



- .1 Sheet Linoleum 2.5mm thick – PREFERRED Resilient Sheet Flooring**
  - .1 Applicable areas: dry areas (corridors, lecture theatres, classrooms, lunchrooms). Acceptable Products:
    - .1 Marmoleum Real - by Forbo Flooring Systems.
    - .2 Linoleum Harmonium XF - by Tarkett / Johnsonite.
- .2 Sheet Vinyl - V1.**
  - .1 Applicable areas: occasionally wet (labs, cafeteria, dining areas, washrooms, etc). Acceptable Products:
    - .1 Preferred: Tarkett iQ Optima or Granit (2.0 mm homogeneous)
    - .2 Acceptable, (limited budget):
      - .1 Armstrong - Connection Corlon, wearing surface: minimum 1.27mm.
      - .2 Tarkett – Contract Plus, 2.0 mm Homogeneous with PUR surface treatment.
- .3 Sheet Vinyl – V2.**
  - .1 Applicable areas: occasionally wet and where chemical resistance is required (labs, chemicals storage, etc). Acceptable Products:
    - .1 Tarkett iQ Optima (GOOD chemical resistance)
    - .2 Tarkett Acczent - Glass or Steel - (EXCELLENT chemical resistance)
- .4 Sheet Vinyl – V3 - Slip Retardant, Safety Flooring:**
  - .1 Applicable areas: wet floors (food service; labs; washrooms, etc). Acceptable products:
    - .1 Labs and Washrooms: Tarkett Safe-T Sheet.
    - .2 Food Service, Ramps, heavy traffic areas: Altro Designer 25
- .5 Sheet Vinyl - V4 - Slip Retardant:**
  - .1 Applicable areas: wet floors (showers, change rooms).
  - .2 Acceptable products - homogeneous, 2.0mm thick, raised texture surface, slip retardant, waterproof c/w flash-coved base:
    - .1 Showers: Tarkett Granit Multisafe and Altro Marine 20 - by Altro Floors
    - .2 Locker & Change Rooms: Tarkett Safe-T Sheet
- .6 Seams:** heat welded, thread in colour to match flooring.
- .7 Guarantee:** five (5) years.
- .8 Accessories**
  - .1 Stair Nosings
    - .1 Stair nosings shall be flexible vinyl, wire reinforced nose, with co-extruded 50mm wide photo-luminescent strip, in colours to be selected from manufacturer's standard range. Acceptable product:
      - .1 Johnsonite Safety-T-First
    - .2 At carpet use double undercut style PIVCD-XX to suit carpet thickness.
    - .3 At linoleum use style PIRCN-XX to suit linoleum thickness.
    - .4 Fill void between nose and tread with Epoxy caulking, to prevent ungluing of nosing.
  - .2 Reducer strips: provide at all exposed edges of flooring materials. Where flooring terminates in a door opening, centre reducer under door.