



**.1 General**

- .1 Main Campus Loop – Industrial type, minimum boiler efficiency of 85%; gas fired.
- .2 Off Campus Loop – Condensing boiler (if supply water temperature demands permit); minimum life span – 20 years.
- 3. Minimum life span to exceed 25 years (industrial grade) for greater than 250,000 btu/hr burner rating (input).