



.1 General

- .1 Materials and installation for contactors for system voltages up to 600 V
- .2 Contactors: to CSA C22.2 No.14.
- .3 Mechanically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
- .4 Fused switch combination contactor as indicated.
- .5 Complete with 2 normally open and 2 normally closed auxiliary contacts unless indicated otherwise.
- .6 Mount in CSA Enclosure 1 unless otherwise indicated.
- .7 Include following options in cover:
 - .1 Red indicating lamp.
 - .2 Stop-Start pushbutton.
 - .3 Hand-Off-Auto or On-Off selector switch, as indicated.
- .8 Control transformer as required.