



.1 System Description

- .1 Provide complete conduit system, including junction boxed and pull string for the installation of a audio-visual systems in lecture theatres, classrooms and video conferencing rooms. The audio-visual systems will be provided by University of Victoria Forces.
- .2 Provide 120 volt power for audio-visual systems and components as required and as indicated.
- .3 Lecture Theatre Audio-Visual infrastructure shall include:
 - .1 Conduit from lecturn cabinets to central dimming controls for respective spaces
 - .2 Conduit from lecture theatre control booths to lecturn cabinet
 - .3 Conduit from control booth to wall mounted and ceiling mounted speakers.
 - .4 Receptacle outlets at lecturn cabinets, minimum 4 circuits and duplex receptacles.
 - .5 Data outlets at lecturn cabinets
- .4 Classroom Audio-Visual infrastructure shall include:
 - .1 Conduit from ceiling overhead projector to lecturn at teaching position
 - .2 Ceiling receptacle for overhead project