



.1 General Flooring Selection Considerations

- .1 Carpet Tile (Refer to Section 9.4)
 - .1 Classrooms
 - .2 Lecture Halls
 - .3 Computer Labs
 - .4 Seminar Rooms
 - .5 Office spaces
 - .6 Meeting and Conference Rooms

- .2 Ceramic Tile (Refer to Section 9.5)
 - .1 Lobbies and Entryways (extend minimum 10m from entrances)
 - .2 Corridors
 - .3 Washrooms and Shower Rooms
 - .4 Lunch Rooms
 - .5 Food Service Spaces

- .3 Linoleum (Refer to Section 9.3)
 - .1 Corridors
 - .2 Lunch Rooms
 - .3 Food Service Spaces
 - .4 Laboratories (non wet)

- .4 Sheet Vinyl (Refer to Section 9.3)
 - .1 Washrooms and Shower Rooms (Small)
 - .2 Laboratories (wet and/or chemical exposure)
 - .3 Janitorial / Utility

- .5 Polished Concrete / Terrazzo
 - .1 Lobbies and Entryways
 - .2 Corridors
 - .3 Mechanical, Electrical and Service Spaces

.2 Matting

- .1 Walk-off Entry Mats
 - .1 Institutional Grade
 - .2 Extend min. 4m from entrances on slip-resistant surfaces and 6m on slippery floors.
 - .1 Matting shall be installed on flush floor; mat wells (depressions) are not acceptable.
 - .2 Acceptable products: min. 7.94 mm thick; nylon polypropylene; vinyl backed, heavy edged and containing min. 30% recycled material:
 - .1 Grizzly FX, or 3M Normad 8850